



NOTES:

1. FOR JOINT USE TRENCH WITH GAS, THE GAS MAIN IS TO BE PLACED ON A SHELF ON THE HOUSE SIDE WITH A MIN. 500MM CLEARANCE MAINTAINED TO HIGH VOLTAGE CABLES.
2. THE POSITION OF ALL POLE LINES, CONDUITS, WATER MAINS SEWERS, AND OTHER UNDERGROUND AND ABOVE GROUND UTILITIES AND STRUCTURES ARE NOT NECESSARILY AS SHOWN. THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK, DETERMINE THE EXACT LOCATION OF ALL SUCH UTILITIES AND STRUCTURES AND ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

Revisions  
 1. Oct 23-06 General  
 rev of trench cross  
 section  
 2. Sept 7, 2023:  
 Revising size of  
 Hydro Duct to  
 100mm



DWN. AHMED KHAIRI

APP. AHMED KHAIRI

DATE SEPT 7, 2023

OTTAWA RIVER POWER CORPORATION

JOINT UTILITY MAIN TRENCH - 4 PARTY  
 DIRECT BURIED

DWG NO. SDUG005

REV  
 2

SCALE NTS

SHEET 1 OF 1